

CERTIFICATE OF COMPLIANCE

Certificate Number 20190108-EX26840
Report Reference EX26840-20181223
Issue Date 2019-JANUARY-08

Issued to: JINAN MEIDE CASTING CO LTD
Meide Science and Technology Park
Pingyin Industrial Park, JINAN
SHANDONG 250400 CHINA

**This certificate confirms that
representative samples of**

VALVES, ALARM

Models ZSFZ8X9 alarm valves in the 3, 4, 6, 6(165.1mm), 6(159.0mm) and 8 in. sizes for a rated pressure of 300, 250, 200, 232, 175 psig for vertical installation, end configuration G by G.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL193, UL Standard for Safety for Alarm Valves for Fire-Protection Service
ULC/ORD -C193-75, Guide for the Investigation of alarm valves for fire-protection service


Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

